


1 PLAN LEVEL 5 - OVERALL FLOOR PLAN
1/8" = 1'-0"



CITY OF DUBLIN APPROVAL



SCHEDULE, RATED ASSEMBLIES AND A600 SERIES SHEETS FOR INTERIOR DETAILS. SHAFT WALL ASSEMBLY TO BE CONTINOUS AND THROUGH THE ROOF. WALL ASSEMBLY TO GO THROUGH THE PODIUM EXCEPT AT SUPPLY AND RETURN AIR FOR RESIDENTIAL CORRIDORS.
PROVIDE A HORIZONTAL SHAFT WALL ASSEMBLY AT THE BOTTOM OF THE SHAFT. SEE THE
GENERAL NOTES ON THIS SHEET FOR ACCESS PANEL REQUIREMENTS AT SHAFT ENCLOSURE.
SEE THE SHAFT ASSEMBLY VERTICAL DETAILS.

33543

**PLAN ELEVATION** ■ PARCEL BOX

LINE INDICATES ORIENTATION OF KEYHOLE FOR FOR ANSI COMPLIANCE SEMI-RECESSED FIRE EXTINGUISHER CABINET. INSTALL FIRE EXTINGUISHER SO THAT THE INTEGRITY OF RATED WALL IS

MAINTAINED. CONTINUE TYPE X GYP BOARD ASSEMBLY

03/29/16
HR SHAFT WALL UNLESS NOTED OTHERWISE , SEE G SERIES SHEETS FOR WALL TYPE

F.E.C. BEHIND FIRE EXTINGUISHER CABINET. UNIT SHALL NOT ENCROACH MORE THAN 4" INTO THE PATH OF EGRESS.

PORTABLE FIRE EXTINGUISHER F.E. HEARING IMPAIRED UNIT, SEE MEP INFORMATION FOR

ADDITIONAL REQUIREMENTS. SEE CODE FLOOR PLANS FOR LOCATIONS

TYPE A FULLY ACCESSIBLE UNIT. SEE CODE FLOOR PLANS FOR LOCATIONS

REQUIRED 30"X48" WHEELCHAIR CLEARANCE. 48" SHALL BE CENTERED AT SINKS AND KITCHEN RANGE 2'-10" MAXIMUM HEIGHT TO THE TOP OF THE KITCHEN OR

ELECTRIC FIRE PLACE AND GYPSUM BOARD SURROUND TYP. AT ALL 1, 2 AND 3-BEDROOM PENTHOUSE UNITS U.N.O.

BATHROOM SINK RIM. TYP. AT PUBLIC AREAS & TYPE A UNITS

VTAC FLOOR PLAN DIAGRAM (VTAC UNIT TO BE INSTALLED AT TYPICA/4) RESIDENTIAL LEVELS. AT PENTHOUSE 2 UNIT INTERIOR LEVEL ONLY, LOCATE CLOSET AND DOOR

**MECHANICAL** LOUVER. PAINT TO MATCH

IN LIEU OF VTAC UNIT) TYPICAL ACCESS PANEL LOCATION FOR MECHANICAL UNIT. ACCESS PANEL TO BE PAINTED TO MATCH ADJACENT WALL.

## **GENERAL NOTES - FLOOR PLAN**

1. ALL DIMENSIONS ARE TO FACE OF WALL (UNLESS NOTED

2. SEE STRUCTURAL DRAWINGS FOR LOCATIONS OF ALL STEEL

REINFORCING IN WALL & FLOOR CONSTRUCTION.

3. SEE FINISH SCHEDULE FOR ADDITIONAL INFORMATION OF LOCATIONS AND TYPES OF FINISH MATERIALS. SEE ELEVATIONS AND STRUCTURAL DRAWINGS FOR LOCATIONS OF EXPANSION & CONTROL JOINTS. CONTRACTOR SHALL PROVIDE ADDITIONAL INTERIOR CONTROL JOINTS AS REQUIRED TO COMPLY

WITH MAXIMUM SPACING REQUIREMENTS IN SPECIFICATIONS AND NATIONAL MASONRY INSTITUTE. SEE DETAILS ON AXXX. MECHANICAL & ELECTRICAL EQUIPMENT SHALL BE ON HOUSEKEEPING PADS. PADS ARE TO PROVIDED BY THE TRADE

SUPPLYING THE EQUIPMENT. SEE MECHANICAL AND ELECTRICAL DRAWINGS FOR ADDITIONAL INFORMATION. WORK TO BE COORDINATED THROUGH THE GENERAL TRADES CONTRACTOR. PADS 4" MIN. 4" THICK W/ W.W.F., UNLESS NOTED OTHERWISE).

. SEE G SERIES SHEETS FOR WALL TYPE CONSTRUCTION. PROVIDE AN 24" X 36" FIRE RATED ACCESS PANEL PER FLOOR AT ALL KITCHEN GREASE SHAFT LOCATIONS AND EVERY OTHER FLOOR FOR ALL OTHER SHAFT LOCATIONS. ACCESS PANELS TO FACE THE PUBLIC CORRIDOR SIDE. COORDINATE MOUNTING HEIGHT WITH


ARCHITECT IN THE FIELD. 8. DO NOT RUN PIPELINE, CONDUITS OR ANY DEVICES INTO THE SHAFT ASSEMBLIES. SHAFT ASSEMBLIES TO REMAIN FOR THE SOLE

PURPOSE OF THE MECHANICAL DUCTS. . ELEVATION 810.00 EQUALS 100'-0" 10. INSTALL FIRE EXTINGUISHER SO THE INTEGRITY OF THE RATED WALL IS MAINTAINED. CONTINUE THE TYPE X GYPSUM BOARD ASSEMBLY BEHIND THE FIRE EXTINGUISHER CABINET.

11. SEE A600 SERIES SHEETS FOR UNIT LAYOUT INFORMATION 12. ALL WOOD SILL PLATES IN WALLS AT PODIUM LEVEL TO BE PRESSURE TREATED.

13. EXTERIOR BEARING WALLS TO BE 1 HOUR RATED. REFER TO STRUCTURAL SHEETS FOR BEARING WALL CONDITIONS. 14. COORDINATE SHAFT WALL ALIGNMENT WITH ARCHITECT TO MAINTAIN REQUIRED RATING IN ADJACENT WALLS.

## **KEY PLAN**



5 07-29-15 Bulletin 1 13 11-23-15 Bulletin 9

**BRIDGE PARK BUILDING C1** 6680 RIVERSIDE DR. DUBLIN, OH 43017



MOODY•NOLAN

RESPONSIVE ARCHITECTURE Phone: (614) 461-4664 Fax: (614) 280-8881

Dwg. Coord.: Author Tech. Coord.: Checker

LEVEL 5 FLOOR PLAN CD PERMIT / GMP SET

A150 02.05.2015

14145